



Government of Tripura  
Directorate of Fire & Emergency Services  
Tripura, Agartala.

Phone: 0381-2326451. Fax: 0381-2324826. Email: [dfireservicetripura@gmail.com](mailto:dfireservicetripura@gmail.com). Website: [www.fireservice.tripura.gov.in](http://www.fireservice.tripura.gov.in)

No.3-8/TFES/2022/ 3125-27

Dated, Agartala, the 29<sup>th</sup> March, 2022.

To  
The Asstt. Headmaster,  
Udaipur English Medium H.S. School,  
Udaipur, Gomati Tripura.  
E-mail: [goutam373@gmail.com](mailto:goutam373@gmail.com), Mob: 9862396233.

Subject: - Issuance of Temporary/Provisional Fire NOC.

Sir,

With reference to your letter Dt. 08/03/2022, it is hereby certified that the building/premises has been inspected by the officer concerned of this department on 22.03.2022. In respect of implementation of Fire Safety measures, it was found that said establishment have complied the Fire Prevention and Fire Safety requirements as per our previous provisional NOC/Advisory issued from this office vide no. 3380/3-8/TFS/2019 dated 30.03.2019. Now in view of present condition of the said establishment there is a need to modify the earlier Fire & Life Safety advisory mentioned above. Fresh/modified Fire & Life Safety Advisory is enclosed herewith.

However, 03 (three) months Temporary NOC is being issued subject to fulfillment of the Fire & Life Safety measures as per Fresh/modified Advisory vide No. 3-8/TFES/2022/ 3122-24 dated 29-3-22

This provision of Fire NOC shall be treated as cancelled ab initio in case the school authority fails to take Fire & Life Safety measures as per Fresh/modified Fire & Life Safety recommendations of Directorate, Home (Fire & Emergency Services), Tripura, Agartala.

Issued on 29-3-22 at Agartala.

N.B. Department is switching over offline issuance of NOC to online shortly. Therefore provisional / Temporary NOC is issued for a period of 03 (three) months. Thereafter, application to be submitted online ([edistrict.tripura.gov.in](http://edistrict.tripura.gov.in)) for Fire NOC.

Yours faithfully,

  
28/03  
Joint Director,

Tripura Fire & Emergency Services.

Conditions for the Validity of Fire NOC.

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all times. Any lapse in this regard shall make the owner /management liable for action.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to the brim.
5. The entrance and exit and the water reservoir should always be free from any obstructions.
6. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

Copy to:

1. The Divisional Fire Officer, Gomati District, Udaipur, Tripura for favour of information.
2. The OC, Udaipur F&ES Station for information.



Government of Tripura  
Directorate of Fire & Emergency Services  
Tripura, Agartala.

Phone: 0381-2326451 Fax: 0381-2324826 Email: [dfireservicetripura@gmail.com](mailto:dfireservicetripura@gmail.com) Website: [www.fireservice.tripura.gov.in](http://www.fireservice.tripura.gov.in)

No. 3-8/TFES/2022/ 3122-24

Dated, Agartala, the 29<sup>th</sup> March, 2022.

To  
The Asstt. Headmaster,  
Udaipur English Medium H.S. School,  
Udaipur, Gomati Tripura.  
E-mail: goutam373@gmail.com, Mob: 9862396233.

Subject:- Fresh/modified Fire & Life Safety Advisory in favour of "Udaipur English Medium H.S. School", Udaipur, Gomati Tripura.

Sir,

It is to inform that Fire Audit team of Fire & Emergency Services Department visited the building/premises of your school on 22.03.2022 and found that Fire Prevention and Fire Safety arrangements in this establishment were installed as per provisional NOC/Advisory issued from this office vide no. 3380/3-8/TFS/2019 dated 30.03.2019.

Now in view of present condition of the said establishment there is a need to modify the earlier Fire & Life Safety advisory mentioned above. So, it is to request to provide the following Fire Prevention and Fire fighting equipments in the said premises/establishment as per recommendations of Part-IV of the latest National Building Code of India (NBC) 2016..

Fire and life safety suggestions:-

A. For Block-1 RCC (G+1) storied school cum administration building

1. 01(one) no. CO<sub>2</sub> fire extinguisher having capacity of 4.5 kg. to be installed near electric main panel board.
2. 01(one) no. CO<sub>2</sub> fire extinguisher having capacity of 02 kg. to be installed near electric sub-panel board.
3. 01(one) no. ABC fire extinguisher (store pressure) having capacity of 04 kg. to be installed alternately at a distance of 15 mtrs. in the corridor of each floor of the building.
4. 01(one) no. CO<sub>2</sub> fire extinguisher having capacity of 02 kg. to be installed inside the H/M room.
5. 02(two) points hose reel hose (length-30 mtrs.) to be installed floor wise. Hose reel hose accessories i.e. 02 nos. delivery hose and 01 no. short branch housed in hose box (double door) to be provided near each hose reel point.
6. Down comer system with landing valve and pressure gauge to be installed and connected with each floor of the building. Mild steel pipe measuring should be not less than 100 mm/04 inch in diameter and 4.5 mm in thickness (B-Class).
7. Terrace level water tank having capacity of 10,000 ltrs. to be constructed exclusively for fire fighting purpose which should be connected with a pump having minimum pressure of 3.5kg/cm<sup>2</sup> with discharge capacity of 450 LPM. Automatic pump controller to be installed/connected with the terrace level pump.
8. 02 ways fire inlet valve to be provided at front side of the building.

B. For Block-2 RCC (G+1) storied school building

1. 01(one) no. CO<sub>2</sub> fire extinguisher having capacity of 02 kg. to be installed near electric sub-panel board.
2. 01(one) no. ABC fire extinguisher (store pressure) having capacity of 04 kg. to be installed alternately at a distance of 15 mtrs. in the corridor of each floor of the building.
3. 01(one) no. CO<sub>2</sub> fire extinguisher having capacity of 02 kg. to be installed inside of computer & laboratory rooms.
4. Single point hose reel hose (length-30 mtrs.) to be installed floor wise. Hose reel hose accessories i.e. 02 nos. delivery hose and 01 no. short branch housed in hose box (double door) to be provided near hose reel point.
5. Down comer system with landing valve and pressure gauge to be installed and connected with each floor of the building. Mild steel pipe measuring should be not less than 100 mm/04 inch in diameter and 4.5 mm in thickness (B-Class).

Contd... P/2

6. Terrace level water tank having capacity of 5,000 ltrs. to be constructed exclusively for fire fighting purpose which should be connected with a pump having minimum pressure of 3.5kg/cm<sup>2</sup> with discharge capacity of 450 LPM. Automatic pump controller to be installed/connected with the terrace level pump.

C. For Block-3 temporary constructed class rooms

1. 01(one) no. CO<sub>2</sub> fire extinguisher having capacity of 02 kg. to be installed near electric sub-panel board.
2. 04(four) nos. ABC fire extinguisher (store pressure) having capacity of 04 kg. to be installed in each room.

D. For Block-4 temporary constructed class rooms

1. 01(one) no. CO<sub>2</sub> fire extinguisher having capacity of 02 kg. to be installed near electric sub-panel board.
3. 03(three) nos. ABC fire extinguisher (store pressure) having capacity of 04 kg. to be installed in each room.

E. For Block-5 kitchen rooms

1. 01(one) no. Wet Chemical fire extinguisher having capacity of 06 ltrs. to be installed in each kitchen room.

Trained fire fighter to be engaged for handling the fire fighting equipments/system while in emergency.

It is to request to arrange for installation of the advised measures. Compliance report may be submitted to this office for further verification which is necessary before issuance of renewal NOC in the next.

Issued on 29-8-22 at Agartala.

Yours faithfully,



Joint Director,  
Tripura Fire & Emergency Services.

Copy to :-

1. The Divisional Fire Officer, Gomati District, Udaipur, Tripura for favour of information.
2. The OC, Udaipur F&ES Station for information.